


G-STRUT 4100 13th Street SW, Canton OH 44710 Phone: 866.997.8788 – Fax: 330.477.0626

www.gregorystrut.com

TWO BOLT UNDERGROUND PIPE CLAMP - SERIES W501



Size Range: 3" through 36" pipe size.

Material: Low Carbon Steel.

Finish: Plain.

Ordering: Specify pipe size; finish and series #,

order Series W503 washer separately.

Function: Designed for clamping the caulked joints

of underground A.W.W.A. ductile iron water pipes to prevent separation of joints.

Available In: Electro-Galvanized.

Note: Clamps must be connected by means of

threaded tie rods and the nuts drawn tight on the washers to assure a tight joint.

| PART # | PIPE SIZE | MAX. PIPE O.D. | Ø SIZE (A) | SIZE (B) | SIZE (C) | SIZE (D) | RECOMMENDED TIE ROD SIZE | LBS./ 100pcs |
|----------|-----------|-------------------|---------------|----------|----------|----------|-----------------------------|-----------------|
| W501130 | 3″ | 3.96 | 5/8 x 3 | 1-1/4" | 9" | 11-3/4" | 3/4" | 618 |
| W501140 | 4" | 4.80 | 5/8 x 3 | 1-1/4" | 10-1/4" | 13" | 3/4" | 880 |
| W501160 | 6" | 6.90 | 5/8 x 3 | 1-1/4" | 12" | 14-7/8" | 3/4" | 1050 |
| W501180 | 8" | 9.05 | 5/8 x 3 | 1-1/4" | 14-1/2" | 17-1/4" | 3/4" | 1234 |
| W5011100 | 10" | 11.10 | 5/8 x 3 | 1-1/4" | 16-3/4" | 19-1/2" | 3/4" | 1480 |
| W5011120 | 12" | 13.20 | 5/8 x 3-1/2 | 1-1/4" | 19" | 21-3/4" | 3/4" | 1603 |
| W5011140 | 14" | 15.30 | 7/8 x 4 | 1-3/8" | 23-3/8" | 27-7/8" | 1" | 4437 |
| W5011160 | 16" | 17.40 | 1 x 4-1/2 | 1-1/2" | 25-1/2" | 29-1/8" | 1-1/8" | 6474 |
| W5011180 | 18" | 19.50 | 1-1/4 × 4-1/2 | 1-1/2" | 28" | 32-1/4" | 1-1/4" | 7369 |
| W5011200 | 20" | 21.60 | 1-1/4 × 4-1/2 | 1-5/8" | 29-3/4" | 33-1/4" | 1-3/8" | 8600 |
| W5011240 | 24" | 25.80 | 1-1/2 x 5 | 1-3/4" | 34" | 37-3/4" | 1-1/2" | 11300 |
| W5011300 | 30" | 32.00 | 1-1/2 × 5-1/2 | 2" | 41-3/8" | 45-1/8" | 1-3/4" | 13678 |
| W5011360 | 36" | 38.30 | 1-1/2 x 5-1/2 | 2-1/2" | 46-1/2" | 50-3/4" | 1-3/4" | 15550 |

All above pipe clamps are plain steel.
To order other finishes, change the 5th character in the Part # as seen below:
ELECTRO-GALVANIZED = 2
Example: W501,2'30 = ELECTRO-GALV

| PROJECT INFORMATION | APPROVAL STAMP | | | |
|---|----------------|--|--|--|
| Project: | Notes: | | | |
| Address: | | | | |
| Contractor: | | | | |
| Engineer: | | | | |
| Date: | | | | |
| Approved Approved as Noted Not Approved | | | | |