



G-STRUT 4100 13<sup>th</sup> Street SW, Canton OH 44710

Phone: 866.997.8788 – Fax: 330.477.0626

[www.gregorystrut.com](http://www.gregorystrut.com)

PART #	FIGURE NO.	PIPE SIZE	ACTUAL THICKNESS OF COVERING	HANGER ROLLER SIZE		CENTER LINE OF PIPE TO CENTER LINE OF SADDLE (C)	CENTER LINE OF PIPE TO CENTER LINE OF ROLLER (D)	MAXIMUM RECOMMENDED LOAD(lbs.)	LBS./100pcs
				series 630	series 610				
W570237	37	4	2-9/16	8	10	5-1/8	6-1/16	1800	343
W570138	38	4	3-1/16	10	10	5-9/16	6-1/4	1800	449
W570139	39	4	1	7	7	4-1/8	4-13/16	1800	262
W570140	40	5	1-1/2	8	8	4-1/2	5-5/16	1800	330
W570141	41	5	2	8	10	4-15/16	5-7/8	1800	345
W570142	42	5	2-9/16	10	12	5-9/16	6-1/2	1800	685
W570143	43	5	3-1/16	10	12	6-1/8	7-1/16	1800	449
W570144	44	5	4-3/16	12	14	7-3/16	8-1/4	1800	609
W570145	45	6	1	8	8	4-9/16	5-3/8	1800	382
W570146	46	6	1-1/2	8	10	5-1/16	5-7/8	1800	428
W570147	47	6	2	10	12	5-1/2	6-1/2	1800	540
W570148	48	6	2-1/2	10	12	6-1/16	7-1/16	1800	685
W570149	49	6	3	12	12	6-9/16	7-5/8	1800	769
W570150	50	6	4-1/8	14	16	7-5/8	9-1/8	1800	1024
W570151	51	8	1-1/2	10	12	6	7-1/8	1800	582
W570152	52	8	2	12	12	6-1/2	7-5/8	1800	641
W570153	53	8	2-11/16	12	14	7-1/4	8-5/16	1800	721
W570154	54	8	3-1/8	14	16	7-5/8	9-1/8	1800	914
W570155	55	8	4-1/8	16	18	8-11/16	10-1/8	1800	1024
W570156	56	10	1-9/16	12	14	7-1/4	8-5/16	1800	666
W570157	57	10	2-1/16	14	16	7-5/8	9-1/16	1800	857
W570158	58	10	2-9/16	14	16	8-3/16	9-5/8	1800	891
W570159	59	10	3-1/16	16	18	8-7/8	10-1/4	1800	1110
W570160	60	10	4-1/16	18	20	9-11/16	11-5/16	1800	1410
W570161	61	12	1-1/2	14	16	8-1/8	9-5/8	5000	761
W570162	62	12	2-1/16	16	18	8-13/16	10-3/16	5000	873
W570163	63	12	2-5/8	16	18	9-1/8	10-11/16	5000	969
W570164	64	12	3-1/16	18	20	9-11/16	11-5/16	5000	1138
W570165	65	12	4-1/8	20	-	10-13/16	12-3/8	5000	1420

PROJECT INFORMATION	APPROVAL STAMP
Project:	Notes:
Address:	
Contractor:	
Engineer:	
Date:	
Approved <input type="checkbox"/> Approved as Noted <input type="checkbox"/> Not Approved <input type="checkbox"/>	